



## **ADDENDUM 1**

### **BID NO. PC20-011 MARTIN THEATRE EXTERIOR WALL REPAIRS RE-BID**

### **FEBRUARY 6, 2020**

The purpose of this addendum is to provide additional information resulting from submitted questions and the answers to those questions.

Q1. Specification Section 05 40 00 refers to spray-applied, fire resistant materials. Sheet A-301 of the contract drawings refers to fire retardant coatings and fire proofing materials. No specification is included for fire resistant materials. Are they included in the scope of work?

A1. No, the fire protection scope will be completed in a later phase. The note under keynote 02.47 refers to the existing fireproof coating to remain. Please revise the specification and drawing as indicated below.

#### **Specification 05 40 00**

- Delete sentence A and B from Section 3.1 of Specification 05 40 00. This scope will be accomplished in a later phase.

#### **Drawing A-301**

- On sheet A-301, delete note "fill cavity with fire proofing where missing". This scope will be accomplished in a later phase.

Acknowledgement of receipt of this addendum is not required. Addenda are posted on the City website and the bidder is responsible to check this site or contact the Purchasing Office at (850) 872-3070, prior to the bid opening to receive a listing of all addenda.